

C-0185-76
15K-G 3/29/76
T-1, R-N



MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY - WASTE AND HAZARDOUS MATERIALS DIVISION

UNDERGROUND STORAGE TANK SYSTEM SITE ASSESSMENT REPORT AND CLOSURE OR CHANGE-IN-SERVICE REGISTRATION FORM

5-0178-08

This information is required under Part 211, Underground Storage Tank Regulations, of the Natural Resources and Environmental Protection Act, Act 451 of the Public Acts of 1994, being Sections 324.21101 to 324.21113 of the Michigan Compiled Laws Annotated. Any owner who knowingly fails to notify or submits false information shall be subject to a misdemeanor and/or civil penalties not to exceed \$5000 per day for each tank for which notification is not given or for which false information is submitted. 20080097

INSTRUCTIONS: For permanent closure and change-in-service, complete all the information on this form and submit with the site assessment analytical results, chain of custody and site sketch which indicates the location and depths of tanks, piping, and samples. This form must be received within 45 days of the samples being taken. The owner is required to keep a copy of the site assessment report for a minimum of three years. See reverse side of this form for additional information.	FACILITY ID NUMBER 00006304
---	--------------------------------

I. OWNERSHIP OF TANKS			II. LOCATION OF TANKS		
NAME OF OWNER (CORPORATION, INDIVIDUAL, ETC.) Hayes Lemmerz International, Inc.			FACILITY NAME OR COMPANY SITE IDENTIFIER OMI-Tech Center, Inc.		
STREET ADDRESS 16300 Centennial Drive			STREET ADDRESS (PO BOX NOT ACCEPTABLE) 1800 West 9 Mile Road		
CITY Northville	STATE Michigan	ZIP CODE 48188	CITY Farmdale	STATE Michigan	ZIP CODE 48220
AREA CODE & TELEPHONE NUMBER (734) 737-5000			CONTACT PERSON FOR LOCATION Mr. Steven D. Thomas	AREA CODE & TELEPHONE NUMBER (734) 737-5168	

III. TANK INFORMATION					
TANK NUMBER	#1	#2			
TANK SIZE	15,000 gallons	15,000 gallons			
SUBSTANCE STORED	Diesel	Gasoline			Waste & Hazardous Materials Division
DATE LAST USED					
DATE CLOSED					
REMOVED FROM GROUND	7/28/08	7/28/08			AUG 29 2008
CLOSED IN PLACE (INDICATE TYPE OF FILL)					
CHANGE-IN-SERVICE					
OWNER'S NAME Hayes Lemmerz International, Inc.	OWNER'S SIGNATURE 			DATE 8/27/08	

IV. SUBMITTER INFORMATION		
SUBMITTED BY (COMPANY NAME) Environmental Consulting & Technology, Inc.		NAME (INDIVIDUAL) Timothy F. Hebert, OPG/REG, CUSTP
SIGNATURE 	DATE 8/27/08	AREA CODE & TELEPHONE NUMBER (517) 272-8200

DO NOT WRITE BELOW THIS LINE (FOR OFFICE USE ONLY)

SITE ASSESSMENT REVIEW REPORT

Your site assessment has been reviewed by the Storage Tank Unit staff and the following determination has been made:

- The contamination concentration is below the threshold detection levels, and there is no evidence of a confirmed release.
- The test methodology or level of detection is faulty. The data submitted is not considered valid. Please perform another site assessment and forward a copy of the results to this office within 45 days.
- The number of sampling points analyzed are considered inadequate to make a determination of the cleanliness of the site. Please perform another site assessment and forward a copy of the results to this office within 45 days.
- The contaminant concentrations are greater than the threshold detection levels and there is evidence of a confirmed release. A confirmed release report is being generated. Follow reporting requirements in accordance with 451 PA 1994, Part 213, as amended.
- The soils excavated and removed from the site were greater than allowable volumes. A confirmed release was not reported to this office within 24 hours per the Michigan Underground Storage Tank Rules (MUSTR) prior to excavation of contaminated soil. A confirmed release report is being generated. Follow reporting requirements in accordance with 451 PA 1994, Part 213, as amended.

SIGNATURE OF REVIEWER	DATE OF REVIEW
-----------------------	----------------

MAIL COPIES TO:

WASTE AND HAZARDOUS MATERIALS DIVISION, STORAGE TANK UNIT
DEPARTMENT OF ENVIRONMENTAL QUALITY
PO BOX 30241 LANSING, MI 48909-7741

EQP3881 (11/05)

BMK SEP 02 2008